


Storage Areas: Outlined areas only are those where the existing consent permits storage

- A** Areas to be used to store the following substances:
2, 3
 - B** No longer required as it relates to the 2012 consent but has been kept to ensure consistency of approach with that consent and the 2013 variation
 - C** Areas to be used to store the following substances:
2, 3, 6, 7
 - D** Areas to be used to store the following substances:
2, 3, 4, 6
 - E** Areas to be used to store the following substances:
2, 3, 4, 5, 6
 - F** Areas to be used to store the following substances:
1, 2, 3, 4, 5, 6
- Butane import from Calor Terminal



Hazardous Substances:

- 1 Gasolines and Naphthas – Part 2 entry no. 34(a) products.
- 2 Kerosenes (including jet fuels) - Part 2 entry no. 34(b) products.
- 3 Gas Oils (including diesel fuels, home heating oils and gas oil blending streams) - Part 2 entry no. 34(c) products.
- 4 Methanol - Part 2 entry no. 22 products.
- 5 Flammable liquids - Part 1 category P5c products (but only those Flammable liquids having a flash point < 21°C).
- 6 Flammable liquids - Part 1 category P5c products (but only those Flammable liquids having a flash point ≥ 21°C and ≤ 55°C).
- 7 Flammable liquids - Part 1 category P5c products but limited only to Ethanol in respect of a liquid having a flash point < 21°C.

NOTE: For the avoidance of doubt, the description given for number 7 above means that the only Flammable liquid with a flash point < 21°C that can be stored in tanks labelled C (Tanks 100 & 101) is Ethanol.